



**Catalog No. ADS06C3F0809B**

**Description: DS-206-3W800ALSIGDA GTU RELT**

**UPC No**

**Home > Conversion Kits & Trip Units > Breaker Conversion Kits - Update Existing Breaker**

Conversion/upgrade kits include everything you need EntelliGuard TU trip unit and rating plug Direct acting flux shifter with automatic reset Epoxy encapsulated high-accuracy current transformers Specially designed mounting hardware and wire harnesses with communication cable and RELT harness for easy upgrade later Detailed instruction manual Base Installation Instructions : DEH-023 EntelliGuard Supplement Instructions : DEH-3456 Trip Unit Installation Instructions : DEH-4567 Entelliguard TU Conversion Kit Brochure : DET722 Note: Depending on your existing installation and the options ordered, additionally accessories/devices may need to be ordered in addition to the conversion kit. Example: RELT will requires 24VDC and also needs a method to turn on RELT, which is GTURSK (RELT Switch Kit). 0809B

**Descriptors**

Category	Breaker Conversion Kits - Update Existing Breaker
GO Schedule	KG

**Specifications**

Manufacturer	Westinghouse
Product Family	L8WECGB
Frame Rating Amps	800
Circuit Breaker Type	DS-206, DSL-206
Generation	C
Wires	3 Wire
Fixed CT's	F
Current Sensor	800 (A)
Trip Function	LSIGDA
Trip Unit Options	Ammeter + RELT
Requires 24VDC	Yes
Includes GTU Cat#	G2108L8X1XRXXXX
Rating Plug Cat#	GTP0800U0820
GSA Compliance	No